

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7167-1645:120

Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: ADEMCO, DBA Honeywell International Inc.,
2 Corporate Center Drive, Ste 100, Melville, New York 11747
Contact: David Kalmus (516) 921-6704 Ext 1910 Fax (516) 364-6953

DESIGN: Model Vista-20, Vista-20SE, Vista-20HW, Vista20-HWSE and Vista-20AMT, Vista-15*, and FA148C* household fire alarm control unit. Power-limited. Unit consists of a single printed wiring board housed within a sheet metal enclosure. The fire loop is intended to be used with the manufacturer's 2000 Ohm end-of-line resistor. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Primary: Class 2, 120 VAC, 16.5 VDC transformer
Secondary: 12 VDC lead acid type battery

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as household fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: 1. **Fire Alarm Verification Feature** (delay of fire alarm signal) is NOT approved for use in California.

2. Formerly 7167-0078:171

*Corrected 03-23-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division

